

PRESENT AND FUTURE OF INDOOR AIR QUALITY

Proceedings of the Brussels Conference,
14-16 February 1989

Editors:

C.J. Bieva, Y. Courtois and M. Govaerts



1989

EXCERPTA MEDICA, Amsterdam – New York – Oxford

2023383817

© 1989 Elsevier Science Publishers B.V. (Biomedical Division)

All rights reserved. No part of this publication may be reproduced, stored in a retrieval system or transmitted in any form or by any means, electronic, mechanical, photocopying, recording or otherwise without the prior written permission of the publisher, Elsevier Science Publishers B.V., Biomedical Division, P.O. Box 1527, 1000 BM Amsterdam, The Netherlands.

No responsibility is assumed by the Publisher for any injury and/or damage to persons or property as a matter of products liability, negligence or otherwise, or from any use or operation of any methods, products, instructions or ideas contained in the material herein. Because of rapid advances in the medical sciences, the Publisher recommends that independent verification of diagnoses and drug dosages should be made.

Special regulations for readers in the USA - This publication has been registered with the Copyright Clearance Center Inc. (CCC), 27 Congress Street, Salem, MA 01970, USA. Information can be obtained from the CCC about conditions under which photocopies of parts of this publication may be made in the USA. All other copyright questions, including photocopying outside the USA, should be referred to the copyright owner, Elsevier Science Publishers B.V., unless otherwise specified.

International Congress Series No. 860
ISBN 0 444 81134 6

This book is printed on acid-free paper.

Published by:
Elsevier Science Publishers B.V.
(Biomedical Division)
P.O. Box 211
1000 AE Amsterdam
The Netherlands

Sole distributors for the USA and Canada:
Elsevier Science Publishing Company Inc.
655 Avenue of the Americas
New York, NY 10010
USA

Printed in The Netherlands

2023383818

FOREWORD

Indoor air quality conservation and procedures for the measurement of related potential pollutants, such as radon, asbestos, gases, pesticides, tobacco smoke and bacteria from air conditioning systems, have seen important changes in recent years, while the range and the scope of the studies have continued to expand.

In addition to helping preserve public health, the field of interest is now extending to include such areas as architectural design, ventilation engineering, sociology, psychology and legal aspects. Related analytical techniques like gas chromatography and mass spectroscopy have undergone parallel refinements and their range of application has broadened.

These advances were discussed at the Conference 'Present and Future of Indoor Air Quality', held in Brussels, February, 1989, following symposia on indoor air quality at Essen and Tokyo in 1987 and London in 1988. The sessions were attended by about 200 scientists representing 20 countries. A total of 92 papers and posters were presented covering such topics as pathogenesis and epidemiology, sources of indoor air contamination and risk assessment, chemistry of indoor air related to the outdoor air quality, social and psychological aspects of poor indoor air quality, motivation and attitudes, future guidelines for the improvement of indoor air quality through architectural and ventilation design, and air quality monitoring.

The proceedings include full texts and posters presented during the meeting. The organising committee hopes that they will constitute a useful guide for the improvement of our indoor air quality in the future.

2023383819

CONTENTS

OPENING SESSION: RISK ASSESSMENT AND HEALTH

Cancer control and lifestyle medicine <i>E.L. Wynder</i>	3
Sick building syndrome - Clinical aspects and prevention <i>C. Molina</i>	15
The ambient air, perceptions and tolerance thresholds: Changing social standards <i>N. Delruelle</i>	23
Concerns and risks of home pollution assessed from the 329 cases reported to a Poison Control Centre during 1987 <i>G. Riboulet-Delmas, R. Garnier and M.-L. Efthymiou</i>	29
Carbon monoxide poisoning: Epidemiology and prevention <i>B. Tissot, M. Govaerts and N. Tinant</i>	37
Current state of research on air quality inside buildings <i>J.C. Loewenstein</i>	43
Radon and lung cancer: A case-control study in southern Belgium <i>A. Poffijn, R. Mak, P. Weynants, M. Vanhoorne and J. Prignot</i>	51
Indoor radon in Belgium <i>A. Poffijn and H. Vanmarcke</i>	55

SECTION 1: ETS AND PASSIVE SMOKING

Environmental tobacco smoke and lung cancer: Is it the smoke or the diet? <i>L.C. Koo</i>	65
Dietary habits are of limited importance in influencing the lung cancer risk among Japanese females who never smoked <i>T. Hirayama</i>	77
An example of extra-poisson variation suggesting an under-specified model <i>S.J. Kilpatrick</i>	83
Lung cancer risk by oral exposure <i>R. Rylander, H.-J. Haussmann and F.J. Tewes</i>	91
Passive smoking: Acute effects on lung function of sensitive persons <i>B. Danuser, A. Weber and A.L. Hartmann</i>	101
Evaluation of exposure to ambient tobacco smoke: A few concrete examples concerning the value of biological and atmospheric indicators <i>A.M. Laurent, Y.A. Courtois, S. Pretet, J.R. Claude and B. Festy</i>	103

2023383820

Exposure to environmental tobacco smoke in the non industrial workplace under different conditions of ventilation and smoking regulation	
<i>T. Sterling, C. Collett and J. Ross</i>	111
Passive smoking and lung cancer; fact or fiction?	
<i>P. Lee</i>	119
Initiatives taken within parents in school to reduce passive smoking risks	
<i>C. Arciti, B. Doglio and L. Santi</i>	129
Health care and society: Environmental tobacco smoke and lung cancer	
<i>E.L. Wynder and G.C. Kabat</i>	135
Isoprene - A potential indoor indicator for environmental tobacco smoke	
<i>G. Löfroth</i>	147
The passive smoking myth	
<i>N. Mantel</i>	155
Relative lung cancer risk from exposure to mainstream and sidestream smoke particulates	
<i>J.J. McAughey, J.N. Pritchard and A. Black</i>	161
Measurement of environmental tobacco smoke in an air-conditioned office building	
<i>C.J. Proctor, N.D. Warren and M.A.J. Bevan</i>	169
Nicotine and indoor air pollution	
<i>C. Arfi, J. Kaloustian, A.M. Pauli, J. Pastor, F. Grimaldi, F. Gouezo and A. Viala</i>	173
Assessing the validity of a Japanese cohort study	
<i>M.W. Layard and J.R. Viren</i>	177

SECTION 2: INDOOR AIR QUALITY: CHEMISTRY AND BIOLOGICAL EFFECTS

Exposure to ETS and its biological effects: A review	
<i>F.X. Adlkofer, G. Scherer, L. Von Meyerinck, Ch. Von Maltzan and L. Jarczyk</i>	189
Carbonyl compounds in mainstream and sidestream cigarette smoke	
<i>H. Schlitt and H. Knöppel</i>	197
Sensory responses to environmental tobacco smoke from cigarettes that heat but do not burn tobacco	
<i>J.C. Walker, R.A. Jennings, W.T. Morgan, J.H. Robinson, D.W. Griffith and J.H. Reynolds IV</i>	207
Role of combustion products in bronchial hyperreactivity - A case control study	
<i>M. Bert, J. Kühr, A. Hendel-Kramer, T. Urbanek, E. Schultz, H. Steiger and W. Karmaus</i>	215
The importance of endotoxin and glucan for symptoms in sick buildings	
<i>R. Rylander, S. Sörensen, H. Goto, K. Yuasa and S. Tanaka</i>	219

2023383821

An epidemiological study on dose-response relationship between B(a)P concentrations in indoor air and lung cancer mortality in Xuan Wei, China <i>He Xingzhou, Chen Wei and Chen Hong</i>	227
Health consequences of atopy, food intolerance and indoor environment: A case study <i>E. Sammaljärvi</i>	235
Assessment of exposure to emissions from a liquefied petroleum gas stove used in urban India <i>V. Haraprasad and J.M. Dave</i>	239
Quality of indoor environment in dwellings according to performance of heating system <i>D. Petráš</i>	243
Oxides of nitrogen and respiratory illness. Is there a susceptible population? <i>J.M. Sneddon and T.M. Bearpark</i>	247
The effect of indoor air pollution on health from coal burning containing high fluorides <i>Ji Rongdi and Cao Shouren</i>	253
Effect of reservoir fuel levels on emissions from a kerosene cook stove <i>J.M. Dave and V. Haraprasad</i>	257
Study of the small-scale relations between indoor and outdoor pollution (SO ₂ - NO _x - particles) in a hospital in the Paris region <i>J.C. Loewenstein</i>	261
Nicotine absorption in humans following exposure to environmental tobacco smoke generated from different types of cigarettes <i>J.D. deBethizy, L.E. Bates, R.A. Davis, D.L. Heavner, P.R. Nelson, J.C. Walker and J.H. Robinson</i>	269
Characterization of the environmental tobacco smoke generated by different cigarettes <i>P.R. Nelson, D.L. Heavner and B.B. Collie</i>	277
Health and social problems of carbon monoxide poisoning from the usage of anthracite coal in Korea <i>Yong Chung, Dongchun Shin and Youngwook Lim</i>	283
On the use of environmental tobacco smoke component ratios <i>G.B. Oldaker III, W.E. Crouse and R.M. Depinto</i>	287

SECTION 3: INDOOR AIR QUALITY: VENTILATION, CLIMATISATION AND POLLUTANTS

Ventilation, health and energy conservation - A workable compromise <i>G. Robertson</i>	293
Ventilation system retrofits as a method of solution for the 'sick building syndrome' <i>C. Collett and E. Sterling</i>	301

2023383822

A few studies of air-conditioned environments <i>A. Mouilleseaux, F. Squinazi and B. Festy</i>	309
Regression model for indoor concentrations of combustion-generated gases <i>A. Hendel-Kramer, J. Kühr, R. Urbanek, H. Staiger, E. Schultz and E. Karmaus</i>	315
A Czechoslovak survey about ventilation habits in dwellings <i>L. Piršel</i>	321
Emissions from materials; The role of additives in PVC <i>K. Saarela, K. Kaustia and A. Kiviranta</i>	329
Influence of indoor air pollution on NO ₂ personal exposure levels of schoolchildren <i>Y. Shimizu, S. Imai and Y. Tsunetoshi</i>	337
Indoor pollution by mineral fibers <i>J. Bignon, G. Dufour, M.A. Billon-Galand, A. Gaudichet, H. de Cremoux and P. Brochard</i>	347
The Acarex/Acarosan concept, its possibilities in allergology and dermatology <i>J.E.M.H. Van Bronswijk, G. Schober and F.M. Kniest</i>	355
Elimination of house dust mite excreta, the carriers of allergens in the indoor air <i>E. Bischoff, A. Fischer and B. Liebenberg</i>	363
Portable air sampler for measurements in aircraft and public buildings <i>J.F. van der Wal</i>	371
Destruction of acarids and biodecontamination of domestic environment <i>M. Blanc and Ch. Boutin</i>	379
Dust in the work environment: Effect of pharmacological agents on the airway response to inhaled cotton dust <i>P.J. Nicholls, M. McDermott, M. Bevan and D. Griffiths-Johnson</i>	385
Moulds, mites and moisture: A preliminary report on six cases of fungal damage in dwellings <i>H.S.M. Kort, J.E.M.H. Van Bronswijk and G. Schober</i>	389
Absolute indoor air humidity and the abundance of allergen producing house dust mites and fungi in the Netherlands <i>G. Schober</i>	395
Air quality control of public car parks <i>F. Cupelin and J.Cl. Landry</i>	401
SECTION 4: INDOOR AIR QUALITY: PREVENTION AND FUTURE GUIDELINES	
Demand controlled ventilating systems: New concepts for indoor air quality and energy conservation <i>L. Trepte</i>	407
A database of problem buildings: Learning by past mistakes <i>C.W. Collett, E.M. Sterling, T.D. Sterling and J.J. Weinkam</i>	413

Treatment programme for microbiologically contaminated airconditioning installations	
<i>E. Clement and R. De Koster</i>	421
Present and future exceedance of health related reference values for air pollutants in Dutch dwellings	
<i>H.J. Van de Wiel and E. Lebre</i>	427
French incentive actions for research on indoor air quality in buildings	
<i>J.-P. Marie, J. Dubois and P.-C. Jacquignon</i>	435
A nitrogen oxide analyser designed for the study of indoor pollution: The APPI-AC35	
<i>B. Millancourt</i>	443
Automatic analyser prototype for atmospheric isoprene and monoterpenes	
<i>M.L. Riba, B. Clement, M. Haziza and L. Torres</i>	449
Air tightness, permeability or transparency to air in buildings, different names for one same problem	
<i>M. Kilberger</i>	453
Index of authors	461

2023383824

A DATABASE OF PROBLEM BUILDINGS: LEARNING BY PAST MISTAKES

C.W. COLLETT and E.M. STERLING
Theodor D. Sterling and Associates Ltd., 20-1507 West 12th Avenue,
Vancouver, British Columbia, V6J 2E2

T.D. STERLING and J.J. WEINKAM
Faculty of Applied Science, School of Computing Science,
Simon Fraser University, Burnaby, British Columbia, V5A 1S6

NOTICE
This material may be
protected by copyright
law (Title 17 U.S. Code).

INTRODUCTION

An implicit objective of the designers of modern office buildings is the creation of a "healthy" work environment, one in which building occupants are satisfied with indoor environmental conditions. However, since the 1970's, it has become apparent that occupants of many buildings are not satisfied, frequently reporting a high prevalence of health and comfort complaints which they relate to their work environment. This dissatisfaction has adversely effected productivity through higher absenteeism and increased stress. This type of problem is commonly referred to as the "Sick Building Syndrome". This syndrome was first recognized in Scandinavia in the early 1970's, and has subsequently been widely studied in other countries of Western Europe and in North America (1,2). The most commonly reported symptoms include eye, nose and throat irritation, headache, fatigue, nausea, dizziness and skin rash or itchiness. In addition, occupants of sick buildings often report comfort problems such as a lack of fresh air, stuffiness, inadequate temperature control and unpleasant odours.

A large number of investigations of sick buildings have now been conducted by government and private sector organizations. These past building investigations offer design professionals a vast quantity of valuable information about "mistakes" made in the past. Designers can learn how to create "healthy buildings" in the future from the mistakes that have caused "sick buildings" in the past.

A DATABASE OF PROBLEM BUILDINGS

An information system, the Building Performance Database (BPD) has been developed as a tool for building professionals and researchers. The BPD currently contains the results of 366

2023383825

building investigations conducted by both government agencies (such as NIOSH and Health and Welfare Canada) and private sector organizations. The BPD is an on-line synthesis of a wide range of information collected by the investigators of sick buildings. The database includes bibliographic information about the investigators and their conclusions, architectural and engineering data, and the results of air quality measurements, building system testing and surveys of occupant health and comfort.

BPD is installed on a mainframe computing system in Canada which can be accessed worldwide through existing communications networks. A more complete description of the analytical capabilities of the BPD has been presented elsewhere (3).

PAST "MISTAKES"

The findings from past investigations can provide useful information to design professionals as they plan future buildings. Knowledge about the causes of past occupant complaints can influence design decisions.

Table One summarizes the conclusions from the 366 reports currently contained in the BPD. Review of the data in BPD shows that in many cases, investigators may identify several factors which they feel had all contributed to the building related problems. Consequently, the table summarizes those factors which have been reported by investigators as contributing to building problems. These factors include ventilation related problems, specific indoor pollutants, stress and ergonomic design. Because investigators have frequently indentified more than one cause in a building, the total number of suspected causes in the table does not equal the number of reports in the BPD. This format differs from tables previously developed by NIOSH and Health and Welfare Canada (4,5,6), which have reported one cause per building (i.e. 400 investigations and 400 suspected causes), which may have oversimplified their results. As the objective of this paper is to provide designers with input into future design decisions, the table provides more detail on specific building problems than those of NIOSH and Health and Welfare Canada.

2023383826

TABLE 1

INVESTIGATOR'S CONCLUSIONS FROM REPORTS CONTAINED IN THE BUILDING PERFORMANCE DATABASE

<u>SUSPECTED CAUSE IDENTIFIED</u>	<u>Number</u>	<u>Percent</u>
VENTILATION CONTROL PROBLEM	159	39.0%
- lack of outside air		
- poor air distribution		
- poor temperature control		
- operational deficiency		
VENTILATION INFILTRATION PROBLEM	40	10.0%
- reentry of exhaust fumes		
- outside infiltration		
INDOOR SOURCES		28.1%
- offgassing from building materials	27	
- printshops/duplicators	17	
- microbial	14	
- smoking	12	
- fibrous insulation	8	
- chemical storage	6	
- cleaning solvents	6	
- pesticides	5	
- lighting	5	
- refrigerant spill	4	
- carpet shampoo	4	
- other (boilers, water leaks, etc.)	7	
STRESS	12	2.9%
ERGONOMIC/WORKSTATION DESIGN	5	1.2%
UNDETERMINED CAUSE	42	10.2%
NO PROBLEM IN BUILDING	35	8.6%
TOTAL	408	100.0%

Ventilation Related Problems

"Ventilation Related" inadequacies are the most commonly reported cause of problems in buildings. A differentiation can be made between problems of "control" and "infiltration".

Ventilation Control Problems. In 39% of the cases contained in BPD, investigators found problems such as inadequate outside air supply, poor air distribution, poor temperature control, a lack of humidification, and various operational deficiencies (such as mechanical failure and poor maintenance practices). All of these causes are "control" problems within the mechanical systems, that

2023383827

can often be corrected with fine tuning of the systems. Although not specifically stated in the report conclusions, ventilation control inadequacies probably contribute to other problems in buildings. For example, in those reports where a specific indoor pollutant was cited as the suspected cause, e.g. offgassing of formaldehyde or smoking, the specific pollutant may have been removed from the building if the mechanical systems had been operating effectively.

Ventilation Infiltration Problems. In 10% of the investigations, the cause of building problems was contamination of the outside air supply, resulting from inappropriate location of an outside air intake. Investigators have identified two distinct causes of infiltration problems. First, reentrainment of air exhausted from the building due to the close proximity of air intake and exhaust vents. Second, infiltration from external sources such as automobiles or industry due to improper location of outside air intakes, e.g. at street level on busy downtown streets, adjacent to loading zones or downwind from industrial plants. Designers of future buildings must make certain that outside air intakes are not located such that reentrainment or external infiltration can occur.

Indoor Sources

Specific sources of indoor pollution were cited as the suspected causes of problems in 28.1% of the reports contained in BPD. The specific sources are identified in the table. The most commonly reported sources include offgassing from various building furnishings and finishing materials (20 reports), contamination from print shops, spirit duplicators and blueprint machines (17 reports), and microbial contamination (14 reports). Microbial contamination may partly also be considered "ventilation related", as problems have occurred as a result of the presence of standing water and dampness in HVAC system components. Smoking has been cited as contributory factor to building problems in 12 reports contained in BPD. Other identified sources include pesticides, insulation materials, carpet shampoo and leakage from boilers and water piping.

Stress

In 12 investigations, stress was reported as a contributory factor to the building related problems. In these cases, investigators were unable to determine a physical cause. However,

2023383828

negative occupant perceptions about the work environment was cited as the main problem. Investigators of problem buildings must take care not to intensify occupant concerns by their presence in the building and "speculation" about building problems prior to final analysis. Recent research has suggested that the presence of investigators in a building may act as a psychological stressor, intensifying occupant belief that problems exist (7). Such problems can be avoided with carefully designed and executed building evaluations. Standardized protocols for building evaluations have been developed by several researchers (8,9).

Ergonomic Design

An important consideration for interior designers is work station design. Although few investigators of sick buildings appear to have considered ergonomic factors, recent research has suggested that VDT work station design is an important factor in occupant comfort for many white collar workers (10). Poor work station design and/or interior layout was cited as a suspected cause of building problems in five reports contained in BPD.

Unidentified Causes

In 42 cases, investigators were unable to determine the cause of building related problems. All environmental parameters were "normal", and mechanical systems were operating according to established standards.

No Problem in Building

In 35 cases, investigators concluded that there was no problem in the building under investigation, i.e. no health hazard existed. In most of these cases, investigators were asked to evaluate the potential for building related problems, rather than responding to specific complaints.

DISCUSSION

A vast array of information is now available to building design professionals and researchers, which identifies the probable reasons for occupant health and comfort complaints in modern office buildings. This information has been (and will continue to be) synthesized into a database information system, which may be accessed by building designers and engineers.

Review of the findings of the investigations contained in this

2023383829

database suggest that some of the problems that have plagued many sick buildings could have been avoided at the design stage. This is not to say that designers should be blamed for all sick building problems. A building may have been appropriately designed, but later actions by the building users has created the problem. For example as a result of energy conservation measures, alteration or the building without attention to the mechanical systems, overcrowding, poor upkeep and maintenance, or introduction of specific sources of pollution to the building. Whatever the cause of past problems in sick buildings, tools such as the BPD will be valuable in the efforts to design healthier work environments in the future, in which occupants will be more satisfied with their indoor environment and consequently more productive.

One final word of caution. The creation of healthy buildings is not solely a design issue. Once a building has been properly designed, building operators and users should practice a preventative approach to ensure that the building stays healthy throughout its life. The design stage should be viewed as the first stage of an ongoing process termed "Building Commissioning", which continues to monitor the functional performance of building through construction and occupancy (11,12).

REFERENCES

1. Stolwijk JAJ (1984) In: Berglund B, Lindvall T, Sundall J (eds) Indoor Air '84. Swedish Council for Building Research, Stockholm, Vol 1, pp 23-30
2. Wallace LA (1988) The Sick Building Syndrome: A Review. Proceedings, 81st Annual Meeting of the Air Pollution Control Association, Dallas, Texas
3. Collett CW, Sterling EM, McIntyre ED, Steeves JF, Weinkam JJ (1987) In: Seifert B (ed) Indoor Air '87. Institute for Water, Soil and Air Hygiene, West Berlin, Vol 2, pp 482-486
4. Melius J, Wallingford K, Keenleyside R, Carpenter J (1984) Annals Am Conf Gov Ind Hyg 10:1-10
5. Crandell MS (1988) NIOSH Indoor Air Quality Investigations: 1971 through 1987. Proceedings, 81st Annual Meeting of the Air Pollution Control Association, Dallas, Texas
6. Kirkbride J (1985) Sick Building Syndrome: Causes and Effects. Health and Welfare Canada Report, Ottawa, Canada

2023383830

7. Hedge A, Sterling EM, Collett CW, Mueller B, Robson R (1987) In: Seifert B (ed) Indoor Air '87. Institute for Water, Soil and Air Hygiene, West Berlin, Vol 2, pp 552-556
8. Woods JE, Morey PR, Rask DR (1987) Indoor Air Quality Diagnostics: Qualitative and Quantitative Procedures to Improve Environmental Conditions. Presentation, Symposium on Design and Protocol for Monitoring Indoor Air Quality. ASTM Symposium, Cincinnati, Ohio
9. Sterling EM, Collett CW, Meredith J (1987) A Five Phased Strategy for Diagnosing Air Quality and Related Ventilation Problems in Commercial Buildings. Proceedings, 80th Annual Meeting of the Air Pollution Control Association, New York
10. Smith MJ, Carayon P, Miezio K (1987) In: Knave B, Wideback PG (eds) Work with Display Units '86. Elsevier Science, Amsterdam, pp 695-712
11. ASHRAE (1988) Proposed Guideline for Commissioning Building Mechanical Systems (Public Review Draft). ASHRAE, Atlanta, Georgia
12. Sterling EM (1988) ASHRAE Transactions, 95(1); CH-89-13-5

2023383831